

SSO Bypass Event Tracker

Event Codes
1= SSO
2= Bypass
3= Basement

| Date | | Time | | Location | | Event | Rainfall Amount | Approx. Discharge | Reporting Party | Sample Taken Y/N | Personnel, arrival time, & Remedy |
|----------|----------|----------|----------|------------------|------------|-------|--------------------|----------------------|-----------------|------------------------|--|
| Begin | End | Begin | End | Manhole ID | Segment ID | | | | | | |
| 01/14/17 | 01/17/17 | 10:35 PM | 6:10 AM | 1801 E. Broadway | | 2 | 3.59 | 5.4 | Wayne Stewart | Y | Plant Hydraulically Overloaded |
| 01/22/17 | 01/23/17 | 1:30 PM | 8:01 AM | 1801 E. Broadway | | 2 | 0.96 | 2.4 | Stephen Myrick | Y | Plant Hydraulically Overloaded |
| 03/24/17 | 03/26/17 | 5:00 PM | 7:45 AM | 1801 E. Broadway | | 2 | 1.84 | 4 | Joe Cornell | Y | Plant Hydraulically Overloaded |
| 03/24/17 | 03/25/17 | 5:30 PM | 3:00 AM | J4-MH-120 | | 1 | 1.66 | 0.02 | Joe Cornell | N | Plant Flow Decreased |
| 03/27/17 | 03/30/17 | 10:00 PM | 6:00 AM | 1801 E. Broadway | | 2 | 0.59 | 6.9 | Joe Cornell | Y | Plant Hydraulically Overloaded |
| 04/21/17 | 04/24/17 | 6:10 AM | 5:30 AM | 1801 E. Broadway | | 2 | 3.11 | 12.8 | Joe Cornell | Y | Plant Hydraulically Overloaded |
| 04/21/17 | 04/22/17 | 7:49 AM | 11:00 AM | J4-MH-120 | | 1 | 3.12 | 3.3 | Joe Cornell | N | Plant Flow Decreased |
| 04/26/17 | 05/07/17 | 2:20 AM | 6:30 PM | 1801 E. Broadway | | 2 | 8.78 | 52.5 | Joe Cornell | Y | Plant Hydraulically Overloaded |
| 04/29/17 | 05/01/17 | 8:00 AM | 3:15 PM | J4-MH-120 | | 1 | 5.65 | 0.91 | Joe Cornell | N | Plant Flow Decreased |
| 04/29/17 | 04/30/17 | 10:00 AM | 10:00 AM | G7-MH-020 | | 1 | 5.68 | 86,000 | Adam Applegate | N | Collection System Was Hydraulically Overloaded |
| 04/29/17 | 04/30/17 | 10:00 | 10:00 AM | F5-MH-040 | | 1 | 5.68 | 144,000 | Adam Applegate | N | Collection System Was Hydraulically Overloaded |
| 04/29/17 | 04/30/17 | 10:00 AM | 10:00 AM | F5-MH-010 | | 1 | 5.68 | 115,000 | Adam Applegate | N | Collection System Was Hydraulically Overloaded |
| 04/29/17 | 04/30/17 | 10:00 AM | 10:00 AM | F5-MH-005 | | 1 | 5.68 | 115,000 | Adam Applegate | N | Collection System Was Hydraulically Overloaded |
| 04/29/17 | 05/01/17 | 10:00 AM | 6:00 AM | J4-MH-090 | | 1 | 5.65 | 0.44 | Joe Cornell | N | Plant Flow Decreased |
| 04/29/17 | 04/30/17 | 10:00 AM | 10:00 AM | G5-MH-175 | | 1 | 5.68 | 150,000 | Adam Applegate | N | Collection System Was Hydraulically Overloaded |
| 05/03/17 | 05/04/17 | 6:00 AM | 5:30 PM | J4-MH-120 | | 1 | 2.64 | 0.62 | Stephen Myrick | N | Plant Flow Decreased |

[illegible]

[illegible]